

Model BT-5550

Product Description

Model No	Nominal Pipe Size		K-Factor	Rated Working Pressure		Remarks
	in	(mm)		psi	(kPa)	
BT-5550	1	(25)	2.8	300	(2065)	a
BT-5550	1	(25)	4.2	300	(2065)	a
BT-5550	1	(25)	5.6	300	(2065)	a
BT-5550	1	(25)	8.0	300	(2065)	a
BT-5550	1 1/4	(32)	2.8	300	(2065)	a
BT-5550	1 1/4	(32)	4.2	300	(2065)	a
BT-5550	1 1/4	(32)	5.6	300	(2065)	a
BT-5550	1 1/4	(32)	8.0	300	(2065)	a
BT-5550	1 1/2	(40)	2.8	300	(2065)	a
BT-5550	1 1/2	(40)	4.2	300	(2065)	a
BT-5550	1 1/2	(40)	5.6	300	(2065)	a
BT-5550	1 1/2	(40)	8.0	300	(2065)	a
BT-5550	2	(50)	2.8	300	(2065)	a
BT-5550	2	(50)	4.2	300	(2065)	a
BT-5550	2	(50)	5.6	300	(2065)	a
BT-5550	2	(50)	8.0	300	(2065)	a

Remarks:

a. Devices supplied with female NPT or female BSPT end connections.

Details

Category	Sprinkler System Alarm Testers
Class of Work	1625 - Branch Line Testers
Approval Standard	FM 1625 - Sprinkler System Alarm Test Devices
Certification Type	FM Approved

Company

BLAZETECH SYSTEMS LTD
 100 AVEBURY BOULEVARD,
 MILTON KEYNES, United Kingdom

Listing Country United
Kingdom