



BT-PSP-1 Supervisory Switch

Certificate Number: **FM26US0167**

Company

BLAZETECH SYSTEMS LTD
100 AVEBURY BOULEVARD, MILTON KEYNES, United Kingdom

Detection, Fire Alarm and Signaling Equipment | Sprinkler Valve Position Devices | **Sprinkler System Supervision, Standard Security**

BT-PSP-1 Supervisory Switch

Description of Equipment:
BT-PSP-1 Plug-in Type Supervisory Switch

Operating Specifications	Detail
SPDT Plug in Contacts	100mA @ 24 VDC/AC 250mA @ 12 VDC/AC
SPDT Cover Tamper Contacts	250mA @ 24 VDC/AC
Operating Temperature Range	-40°C to 60°C
Suitable location of operation	Indoor/Outdoor use

Details

Category	Sprinkler System Supervision, Standard Security
Class of Work	3135 - Sprinkler Valve Pos Sw
Certification Type	FM Approved
Listing Country	United Kingdom
Certificate Number	FM26US0167