

# Model BT 5402

File Number: EX29990

**COMPANY**  
**Blazetech Systems Ltd**  
100 Avebury Boulevard  
Milton Keynes, MK9 1FH United Kingdom

**MODEL INFO**  
BT 5402  
Butterfly Valve

| ATTRIBUTES AND RATINGS          |                   |                             |                |                                           |
|---------------------------------|-------------------|-----------------------------|----------------|-------------------------------------------|
| Size, NPS                       | End Configuration | Pressure Rating, psig (kPa) | Indicator Post | Supervisory Tamper Switch                 |
| 2, 2-1/2, 3, 4, 5, 6, 8, 10, 12 | Groove            | 300 (2068)                  | No             | Indoor installation, Outdoor installation |

Report Date: 2026-07-17  
Revision Date: 2026-07-17

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2026 UL LLC."