



Extinguishing System Attachments

COMPANY

Blazetech Systems Ltd  
100 Avebury Boulevard  
Milton Keynes, MK9 1FH United Kingdom

S37200

SPRINKLER SYSTEM ALARM INITIATING DEVICES

Wet pipe, paddle type

| Model      | Size<br>In. | Pipe<br>Schedule | Max System<br>Pressure psig |
|------------|-------------|------------------|-----------------------------|
| BT-WFD-050 | 2           | 10 thru 40       | 300                         |
| BT-WFD-065 | 2.5         | 10 thru 40       | 300                         |
| BT-WFD-080 | 3           | 10 thru 40       | 300                         |
| BT-WFD-100 | 4           | 10 thru 40       | 300                         |
| BT-WFD-150 | 6           | 10 thru 40       | 300                         |
| BT-WFD-200 | 8           | 10 thru 40       | 300                         |

Valve Supervisory Switches, Models BT-PIV-01, BT-OSY-01, and BT-PSP-01



Trademark and/or Tradename: "BLAZE" , "BT" ,

Last Updated on 2026-07-28

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2026 UL LLC."