

Fixed Extinguishing Systems | Deluge and Preaction Systems | **Dry Pipe System Valves**

BT 5940F, BT 5940FG and BT 5940G

Product Description

Model No	Valve Size		Rated Working Pressure		End Connection	Remarks
	in	(mm)	psi	(kPa)		
BT 5940F	3, 4, 6, 8	(80, 100, 150, 200)	300	(2065)	Flanged x Flanged	a, b, c, d
BT 5940FG	3, 4, 6, 8	(80, 100, 150, 200)	300	(2065)	Flanged x Grooved	a, b, c, d
BT 5940G	3, 4, 6, 8	(80, 100, 150, 200)	300	(2065)	Grooved x Grooved	a, b, c, d

Remarks:

a. Approved for vertical installation only

b. Approved when supplied with a main control valve body ASTM A536 ductile iron

c. Approved when supplied with FM Approved pressure gauges

d. Approved when supplied with one or more of the following optional components: dry accelerator assembly, FM Approved pressure switch and FM Approved water motor gong.

Details

Category	Dry Pipe System Valves
Class of Work	1021 - Dry Pipe Valves
Approval Standard	FM 1021 - Dry Pipe Valves
Certification Type	FM Approved
Listing Country	United Kingdom

Company

BLAZETECH SYSTEMS LTD
100 AVEBURY BOULEVARD,
MILTON KEYNES, United Kingdom