



SIN BL 5612

File Number: EX30031

COMPANY
Blazetech Systems Ltd
100 Avebury Boulevard
Milton Keynes, MK9 1FH United Kingdom

SIN INFO
BL 5612
Glass Bulb Type

ATTRIBUTES

Response Type	Sprinkler Type	Nom K-Factor, gpm/vpsi (L/min/vbar)	System Working Pressure	Corrosion Resistant
QR	Standard-Spray Sprinklers, Upright And Pendent, Intermediate Level Sprinklers	8.0 (115)	175 psig (1.2 Mpa)	Not Available

GENERAL

Inlet Connection

3/4 in. NPT

STANDARD-SPRAY SPRINKLERS, UPRIGHT AND PENDENT

Type	Sprinkler Temp Rating, °F (°C)	Cover Temp Rating, °F (°C)
Pendent, Rec. Pendent	135 (57), 155 (68), 175 (79), 200 (93)	Not Applicable

INTERMEDIATE LEVEL SPRINKLERS

Type	Sprinkler Temp Rating, °F (°C)
Pendent	135 (57), 155 (68), 175 (79), 200 (93)

Report Date: 2026-08-24
Revision Date: 2026-08-24

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2026 UL LLC."