



Model BT 5560T

File Number: EX30045

COMPANY
Blazetech Systems Ltd
100 Avebury Boulevard
Milton Keynes, MK9 1FH United Kingdom

MODEL INFO
BT 5560T
Flow detection and test assembly

PRODUCT INFORMATION		
Nominal Pipe Size	Body Material	Rated Pressure, psig (kPa)
2 in.	Schedule 40 Pipe	300 (2068)
2-1/2 in.	Schedule 40 Pipe	300 (2068)
76.1 mm	Schedule 40 Pipe	300 (2068)
3 in.	Schedule 40 Pipe	300 (2068)
4 in.	Schedule 40 Pipe	300 (2068)
165.1 mm	Schedule 40 Pipe	300 (2068)
6 in.	Schedule 40 Pipe	300 (2068)
8 in.	Schedule 40 Pipe	300 (2068)

Report Date: 2026-09-22
Revision Date: 2026-09-22

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2026 UL LLC."