



Model BT 5850V (25–3963 Gallon)

File Number: EX30022

COMPANY
Blazetech Systems Ltd
100 Avebury Boulevard
Milton Keynes, MK9 1FH United Kingdom

MODEL INFO
BT 5850V (25–3963 Gallon)
RATIO-FLOW CONTROLLER WITH BLADDER TANK

RATIO-FLOW CONTROLLER WITH BLADDER TANK

Evaluation Standard

UL 162, UL Subject 139

GENERAL

Bladder Tank Description

Controller Model BT 5851

GENERAL

Size, in.	End Configuration	Eq. Len. of 130 roughness factor Sch 40 pipe, ft.
2	Wafer	22
3	Wafer	17.5
4	Wafer	29.3
6	Wafer	24.9
8	Wafer	23

Report Date: 2026-08-17

Revision Date: 2026-09-17

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2026 UL LLC."